



ఆంధ్రప్రదేశ్ రాజ పత్రము
THE ANDHRA PRADESH GAZETTE
PUBLISHED BY AUTHORITY

PART I EXTRAORDINARY

No.121

AMARAVATI, THURSDAY, MARCH 12, 2026

G.1189

NOTIFICATIONS BY GOVERNMENT

--X--

ENERGY DEPARTMENT
(POWER-II)

THE ELECTRICITY ACT, 2003- CENTRAL ELECTRICITY AUTHORITY (MEASURES RELATING TO SAFETY AND ELECTRIC SUPPLY) REGULATIONS, 2023 - ANDHRA PRADESH DIRECTORATE OF ELECTRICAL SAFETY (MEASURES RELATING TO SAFETY AND ELECTRIC SUPPLY) ORDER, 2026.

(G.O.Ms.No.17, Energy (Power-II), 11th March, 2026.)

NOTIFICATION-I

In exercise of the powers conferred by the clause (zu) of sub-regulation (1) of regulation 2 of the Central Electricity Authority (Measures Relating to Safety and Electric Supply) Regulations, 2023 and in supersession of earlier Orders issued on the same subject, the Government hereby notifies 33 KV as the notified voltage up to which Self-certification is to be carried out under regulations 32 and 45 of the said Regulations.

NOTIFICATION-II

In exercise of the powers conferred by sub-regulation (2) of regulation 32 of the Central Electricity Authority (Measures Relating to Safety and Electric Supply) Regulations, 2023 and in supersession of earlier Orders issued on the same subject, the Government hereby directs that the periodicity of electrical inspection by the Electrical Inspector shall be as follows:

1. Once in a year in respect of installations of voltage above 33 KV as notified belonging to the Owner or consumer or supplier shall be carried out by the Electrical Inspector.
2. Once in a year in respect of installations below or equal to the notified voltage shall be self-certified by the Owner or consumer or supplier as the case may be.
3. However, the above directions are subject to the-general safety requirements under regulation 32.

NOTIFICATION-III

In exercise of the powers conferred by regulation 34 of the Central Electricity Authority (Measures Relating to Safety and Electric Supply) Regulations, 2023 and in supersession of earlier Orders issued on the same subject, the Government hereby notifies 10 KW as the capacity above which generating units including generating units producing electricity from renewable sources of energy shall be required to be inspected by the Electrical Inspector, before commissioning.

Provided that the Generating Units including generating units producing electricity from renewable sources of energy especially the Solar Units under the scheme "Prime Minister Surya Ghar Mufth Bijli Yojana" shall be self-certified by the owner or the Consumer with a view to encourage the scheme PMSG:MBY, and to continue the commitment to the renewable energy transition:

Provided further that the owner or the Consumer shall provide the protection scheme such that when there is no incoming supply owing to an outage in the network or load shedding by the Discoms, under no circumstances, there be any power injection from Solar Roof Top Units into the Grid, to prevent back feeding and thus accidents.

NOTIFICATION-IV

In exercise of the powers conferred by regulation 38 of the Central Electricity Authority (Measures Relating to Safety and Electric Supply) Regulations, 2023 and in supersession of earlier Orders issued on the same subject, the Government hereby notifies that all installations of voltage of supply Exceeding 11 KV at the point of commencement of supply (irrespective of connected load) of Multi- Storied Buildings of more than fifteen metres in height, shall be carried out by the Electrical Inspector duly following the provisions under the said regulation scrupulously.

NOTIFICATION-V

In exercise of the powers conferred by regulation 45 of the Central Electricity Authority (Measures Relating to Safety and Electric Supply) Regulations, 2023 and in supersession of earlier Orders issued on the same subject, the Government hereby notifies 33 KV as the voltage above which inspection and testing of electrical installations of supplier or Consumer shall be carried out by the Electrical Inspector. Every Electrical installation of notified voltage and below shall be inspected, tested

and self-certified by the owner or supplier or consumer as the case may be duly following the provisions as referred to in the said regulation

K. VIJAYANAND,
Special Chief Secretary to Government (FAC).

---X---